

CITY PLAN COMMISSION

THURSDAY, January 15, 2026

FILE NUMBER: PLAT-25-000162

SENIOR PLANNER: Hema Sharma

LOCATION: Telephone Road at Blanco Drive, southwest corner.

DATE FILED: December 17, 2025

ZONING: PD 761 (LI)

PD LINK: <https://dallascityhall.com/departments/city-attorney/Articles/PDF/Article%20761.pdf>

CITY COUNCIL DISTRICT: 8

SIZE OF REQUEST: 9.948-acres

APPLICANT/OWNER: K3E Holdings, LLC

REQUEST: An application to create one 9.948-acre lot from a tract of land in City Block 8313 on property located on Telephone Road at Blanco Drive, southwest corner.

SUBDIVISION HISTORY:

1. S201-569 was a request west of the present request to create one 10.8250-acre lot from a tract of land in City Block 8313 on property located on Telephone Road at Bonnie View Road, southeast corner. The request was approved on February 18, 2021, and was recorded on February 16, 2023.

STAFF RECOMMENDATION: The request complies with the requirements of the PD 761 (LI); therefore, staff recommends approval of the request subject to compliance with the following conditions:

General Conditions:

1. The final plat must conform to all requirements of the Dallas Development Code, Texas Local Government Code, Texas Land Surveying Practices Act and the General Rules and Regulations of the Texas Board of Land Surveying.
2. Department of Development Services, Engineering Division must verify that the plat conforms with the water, wastewater, and easement requirements under the provisions of Chapter 49 of the Dallas City Code.
3. Compliance with all plans, contracts, ordinances, and requirements of the City of Dallas. *Section 51A-8.102(a), (b), (c), and (d)*
4. The number and location of fire hydrants must comply with the Dallas Fire Code.
5. Any new or existing structure may not extend across new property lines. *Section 51A-8.503(e)*
6. On the final plat, all easement abandonments, and ROW abandonments must be by separate instrument with the recording information shown on the face of the plat. A release from the Real Estate Division is required prior to the plat being submitted to the Chairman for signature.
7. On the final plat, include two boundary corners tagged with these coordinates: "Texas State Plane Coordinate System, North Central Zone, North American Datum of 1983 on Grid Coordinate values, No Scale and no Projection."

8. On the final plat, monument all set corners per the Monumentation Ordinance. Prior to submittal of the final plat for the Chairman's signature. The monuments must be verified by the Chief City Surveyors Office in the Public Works Department. *Section 51A-8.617*
9. Provide ALL supporting documentation (i.e. deeds, plats, ordinances, easements...etc) with a completed Final Plat Checklist to the Survey Plat Review Group (**SPRG**) with the Final Plat Submittal after City Plan Commission Approval.
10. Prior to the final plat, submit a tree survey to the Arborist. A release from the arborist is required prior to an early release request or the recordation of the plat, whichever occurs first.
11. The number of lots permitted by this plat is one.

Paving & Drainage Conditions:

12. Submit a full set of Civil Engineering Plans (drainage, paving, street signage/marking/lighting) prepared per City Standards by a licensed (TX) Professional Engineer to Engineering Division in Room 200, Oak Cliff Municipal Center (i.e. 311T/DP). Additions and alterations to the public infrastructure require approval and may require private development contracts with bonds.51A- 8.102 (c); 8.601(b)(4),(5),(6),(7),(8),(9)
13. Detention may be required if the capacity of available outfall is not adequate to carry the developed runoff. *Section 51A-8.611(c)*.
14. "Lot-to-Lot drainage will not be allowed without proper City of Dallas Engineering Division approval" (Note must be on the Plat). *51A 8.611(e)*

Right-of way Requirements Conditions:

15. On the final plat, dedicate 28 feet of right-of-way (via fee simple or street easement) from the established centerline of Telephone Road. *Sections 51A-8.602(c), 51A-8.604(c) and 51A-8.611(c)*.
16. On the final plat, dedicate 28 feet of right-of-way (via fee simple or street easement) from the established centerline of Blanco Road. *Sections 51A-8.602(c), 51A-8.604(c) and 51A-8.611(c)*.
17. On the final plat, dedicate a minimum 5-foot by 5-foot corner clip (via fee simple or street easement) at the intersection of Telephone Road & Blanco Road. *Section 51A 8.602(d)(1)*
18. A larger corner clip may be requested during engineering plan and traffic review to accommodate an adequate turning radius, or to maintain public/traffic appurtenances, within the area of the corner clip. *Section 51A 8.602(d)(1), 51A 8.608(a)*

Flood Plain Conditions:

19. On the final plat, determine the 100-year water surface elevation across this addition.

20. On the final plat, dedicate floodway easement, floodway management area or floodway easement (within common area), with the appropriate easement statement included on the face of the Plat. 51A 8.611(d); DWU Floodplain Management; Drainage Design Manual Addendum V
21. On the final plat, include additional paragraph in Owner's Certificate (pertaining to the floodplain). 51A 8.611(d); DWU Floodplain Management; Drainage Design Manual Addendum V
22. On the final plat, specify minimum fill and minimum finished floor elevations. *Section 51A-8.611(d), Trinity Watershed Management.*
23. On the final plat, show the natural channel set back from the crest of the natural channel. *Section 51A-8.611(d), Trinity Watershed Management.*
24. Prior to submission of the final plat, set floodway monument markers and provide documentation that the monuments have been set. *Section 51A-8.617(d)(1), (2), (3), and (4)*
25. Provide information regarding Fill Permit or Floodplain Alteration Permit if such permit is applied for.

Survey (SPRG) Conditions:

26. Prior to final plat, submit a completed final plat checklist and all supporting documents.
27. On the final plat, show how all adjoining right-of-way was created. *Section 51A-8.403(a)(1)(A)(xxii).*
28. On the final plat, show distances/width across all adjoining right-of-way
29. On the final plat, show recording information on all existing easements within 150 feet of the property.
30. On the final plat, show all additions or tracts of land within 150 feet of the property with recording information. *Platting Guidelines.*
31. On the final plat, plat number cannot start with number.


Dallas Water Utilities Conditions:

32. Additional design information is required for assessment. Site plan must be submitted showing proposed development, building finished floor elevation, development, existing mains – including downstream manhole, and proposed water and wastewater service locations. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.
33. Water main improvements may be required by Private Development Contract. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.
34. Wastewater main improvements is required by Private Development Contract. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.

35. Existing and any proposed Water and Wastewater Easements must be shown and/or increased to conform to current design standards. **Notice:** Minimum DWU easement size 20' for one utility and 25' for both water and sewer. Larger diameter or deeper mains may require additional width.


Street Light/ GIS, Lot & Block Conditions:

36. Additional design information needed to complete review. Provide a brief description of the proposed project and a copy of the site plan to daniel.silva1@dallas.gov to determine street lighting requirements.
37. On the final plat, identify the property as Lot 1 in City Block C/8313.






 1:3,600	AERIAL MAP <input type="checkbox"/> Area Of Request <input type="checkbox"/> Recent History	Case no: PLAT-25-000162 Date: 12/29/2025
--	--	---



City Plan Commission Date: 01/15/2026

36(g)

PLAT-25-000162



City Plan Commission Date: 01/15/2026

36(h)

PLAT-25-000162

