

CITY PLAN COMMISSION**THURSDAY, January 15, 2026****FILE NUMBER:** PLAT-25-000172**SENIOR PLANNER:** Hema Sharma**LOCATION:** Wheatland Road, east of County View Road**DATE FILED:** December 18, 2025**ZONING:** MF-2(A)**CITY COUNCIL DISTRICT:** 3**SIZE OF REQUEST:** 3.775-acres**APPLICANT/OWNER:** TX James Apts. 2025 LTD

REQUEST: An application to create one 3.775-acre lot from a tract of land in City Block 10/8604 on property located on Wheatland Road, east of County View Road.

SUBDIVISION HISTORY:

1. S212-111R was a request east of the present request to revise a previously approved preliminary plat (S212-111) to replat a 1.162-acre tract of land containing all of Lot 3 and tract of land in City Block 8604 to create one 0.966-acre lot and one 0.166-acre lot on property located on Wheatland Road, west of Clark Road. The request was approved on June 6, 2024, but has not been recorded.

STAFF RECOMMENDATION: Section 51A-8.503 states that “lots must conform in width, depth and area to the pattern already established in the adjacent areas, having due regard to the character of the area, its particular suitability for development, and taking into consideration the natural topography of the ground, drainage, wastewater facilities, and the proposed layout of the streets.”

The request lies in MF-2(A) Multi Family District which has a minimum lot area requirement of 1,000 square feet for single family structures and 6,000 square feet for duplex structures. The minimum lot area for multifamily structures depends on the number of bedrooms. The proposed lot area is 3.775-acres.

Staff finds that there is a variation in the lot pattern within the immediate vicinity of the request (refer to the existing analysis map and aerial map). The request complies with the zoning requirement of the MF-2(A) Multifamily District and is in compliance with Section 51A-8.503; therefore, staff recommends approval subject to compliance with the following conditions:

General Conditions:

1. The final plat must conform to all requirements of the Dallas Development Code, Texas Local Government Code, Texas Land Surveying Practices Act and the General Rules and Regulations of the Texas Board of Land Surveying.
2. Department of Development Services, Engineering Division must verify that the plat conforms with the water, wastewater, and easement requirements under the provisions of Chapter 49 of the Dallas City Code.
3. Compliance with all plans, contracts, ordinances, and requirements of the City of Dallas. *Section 51A-8.102(a), (b), (c), and (d)*

4. The number and location of fire hydrants must comply with the Dallas Fire Code.
5. Any new or existing structure may not extend across new property lines. *Section 51A-8.503(e)*
6. On the final plat, all easement abandonments, and ROW abandonments must be by separate instrument with the recording information shown on the face of the plat. A release from the Real Estate Division is required prior to the plat being submitted to the Chairman for signature.
7. On the final plat, include two boundary corners tagged with these coordinates: "Texas State Plane Coordinate System, North Central Zone, North American Datum of 1983 on Grid Coordinate values, No Scale and no Projection."
8. On the final plat, monument all set corners per the Monumentation Ordinance. Prior to submittal of the final plat for the Chairman's signature. The monuments must be verified by the Chief City Surveyors Office in the Public Works Department. *Section 51A-8.617*
9. Provide ALL supporting documentation (i.e. deeds, plats, ordinances, easements...etc) with a completed Final Plat Checklist to the Survey Plat Review Group (**SPRG**) with the Final Plat Submittal **after** City Plan Commission Approval.
10. Prior to the final plat, submit a tree survey to the Arborist. A release from the arborist is required prior to an early release request or the recordation of the plat, whichever occurs first.
11. The number of lots permitted by this plat is one.

Paving & Drainage Conditions:

12. Submit a full set of Civil Engineering Plans (drainage, paving, street signage/markings/lighting) prepared per City Standards by a licensed (TX) Professional Engineer to Engineering Division in Room 200, Oak Cliff Municipal Center (i.e. 311T/DP). Additions and alterations to the public infrastructure require approval and may require private development contracts with bonds. 51A- 8.102 (c); 8.601(b)(4),(5),(6),(7),(8),(9)
13. Detention may be required if the capacity of available outfall is not adequate to carry the developed runoff. *Section 51A-8.611(c)*.
14. "Lot-to-Lot drainage will not be allowed without proper City of Dallas Engineering Division approval" (Note must be on the Plat). 51A 8.611(e)

Right-of way Requirements Conditions:

15. On the final plat, dedicate 50 feet of right-of-way (via fee simple) from the established center line of Wheatland Road. *Section 51A 8.602(c)*
16. On the final plat, dedicate a 15-foot by 15-foot Alley Sight Easement at the intersection of Alley & the alley. *Section 51A-8.602(e)*
17. Provide minimum alley ROW at the alley bend per City of Dallas Standard Construction Details File 251D-1 Page 1012.

Survey (SPRG) Conditions:

18. Prior to final plat, submit a completed final plat checklist and all supporting documents.
19. On the final plat, show recording information on all existing easements within 150 feet of the property.
20. On the final plat, show all additions or tracts of land within 150 feet of the property with recording information. Platting Guidelines.

Dallas Water Utilities Conditions:

21. Additional design information is required for assessment. Site plan must be submitted showing proposed development, building finished floor elevation, development, existing mains – including downstream manhole, and proposed water and wastewater service locations. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.
22. Water and Wastewater main improvements is required by Private Development Contract. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.
23. Existing and any proposed Water and Wastewater Easements must be shown and/or increased to conform to current design standards. **Notice:** Minimum DWU easement size 20' for one utility and 25' for both water and sewer. Larger diameter or deeper mains may require additional width.

Street Light/ Street Name/ GIS, Lot & Block Conditions:

24. Additional design information needed to complete review. Provide a brief description of the proposed project and a copy of the site plan to daniel.silva1@dallas.gov to determine street lighting requirements.
25. On the final plat, change "Sugarberry Road" to "Sugarberry Place". Section 51A-8.403(a)(1)(A)(xii).
26. On the final plat, add "Boisenberry Lane"
27. On the final plat, identify the property as Lot 4 in City Block 10/8604.

ALL AREAS ARE IN SQUARE FEET







