CITY PLAN COMMISSION

THURSDAY, NOVEMBER 6, 2025

RECORD NO.: Plat-25-000117 SENIOR PLANNER: Sharmila Shrestha

LOCATION: bounded by Indian Ridge Trail, Kirnwood Drive, Forest Meadow Trail, and

Goldwood Drive

DATE FILED: October 10, 2025 **ZONING:** R-7.5(A)

CITY COUNCIL DISTRICT: 8 SIZE OF REQUEST: 9.119-acres

APPLICANT/OWNER: Dallas Independent School District

REQUEST: An application to create one 9.119-acre lot from a tract of land in City Block 7569 on property bounded by Indian Ridge Trail, Kirnwood Drive, Forest Meadow Trail, and Goldwood Drive.

SUBDIVISION HISTORY: There has been no recent platting activity within close proximity to this request.

STAFF RECOMMENDATION: Section 51A-8.503 states that "lots must conform in width, depth, and area to the pattern already established in the adjacent areas, having due regard to the character of the area, its particular suitability for development, and taking into consideration the natural topography of the ground, drainage, wastewater facilities, and the proposed layout of the streets."

The lots are being created from a tract of land; therefore, it does not qualify for a residential replat and can be approved on the consent agenda.

It is a policy of the city that institutional uses generally require greater land area than traditional residential or non-residential lots and generally serve, and are compatible with the neighborhood; therefore, staff concludes that the request is in compliance with Section 51A-8.503 and with the requirements of R-7.5(A) Single Family District; therefore, staff recommends approval of the request subject to compliance with the following conditions:

General Conditions:

- 1. The final plat must conform to all requirements of the Dallas Development Code, Texas Local Government Code, Texas Land Surveying Practices Act and the General Rules and Regulations of the Texas Board of Land Surveying.
- 2. Department of Development Services, Engineering Division must verify that the plat conforms with the water, wastewater, and easement requirements under the provisions of Chapter 49 of the Dallas City Code.
- 3. Compliance with all plans, contracts, ordinances, and requirements of the City of Dallas. Section 51A-8.102(a), (b), (c), and (d)
- 4. The number and location of fire hydrants must comply with the Dallas Fire Code.
- 5. Any new or existing structure may not extend across new property lines. Section 51A-8.503(e)

- 6. On the final plat, all easement abandonments, and ROW abandonments must be by separate instrument with the recording information shown on the face of the plat. A release from the Real Estate Division is required prior to the plat being submitted to the Chairman for signature.
- 7. On the final plat, include two boundary corners tagged with these coordinates: "Texas State Plane Coordinate System, North Central Zone, North American Datum of 1983 on Grid Coordinate values, No Scale and no Projection."
- 8. On the final plat, monument all set corners per the Monumentation Ordinance. Prior to submitting the final plat for the Chairman's signature. The monuments must be verified by the Chief City Surveyors Office in the Public Works Department. Section 51A-8.617
- 9. Provide ALL supporting documentation (i.e. deeds, plats, ordinances, easements...etc) with a completed Final Plat Checklist to the Survey Plat Review Group (**SPRG**) with the Final Plat Submittal <u>after</u> City Plan Commission Approval.
- 10. Prior to the final plat, submit a tree survey to the Arborist. A release from the arborist is required prior to an early release request or the recordation of the plat, whichever occurs first.
- 11. The number of lots permitted by this plat is one.

Paving & Drainage Conditions:

- 12. Submit a full set of Civil Engineering Plans (drainage, paving, street signage/marking/lighting) prepared per City Standards by a licensed (TX) Professional Engineer to Engineering Division in Room 200, Oak Cliff Municipal Center (i.e. 311T/DP). Additions and alterations to the public infrastructure require approval and may require private development contracts with bonds.51A-8.102 (c); 8.601(b)(4),(5),(6),(7),(8),(9)
- 13. Detention may be required if the capacity of available outfall is not adequate to carry the developed runoff. Section 51A-8.611(c).
- 14. Place a note on the final plat stating "Lot-to-Lot drainage will not be allowed without proper City of Dallas Engineering Division approval" 51A 8.611(e)

Right-of way Requirements Conditions:

- 15. On the final plat, dedicate a minimum 5-foot by 5-foot corner clip (via Fee Simple or Street Easement) at Kirnwood Drive and Indian Ridge Trail, Goldwood Drive and Indian Ridge Trail. Section 51A 8.602(d)(1).
- 16. A larger corner clip may be requested during engineering plan and traffic review to accommodate an adequate turning radius, or to maintain public/traffic appurtenances, within the area of the corner clip. 51A 8.602(d)(1), 51A 8.608(a)

Survey (SPRG) Conditions:

17. Submit a completed Final Plat Checklist and All Supporting Documentation.

Dallas Water Utilities Conditions:

- 18. Additional design information is required for assessment. Site plan must be submitted showing proposed development, building finished floor elevation, development, existing mains including downstream manhole, and proposed water and wastewater service locations. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.
- 19. Water and Wastewater main improvements may be required by Private Development Contract. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.

Street Light/ GIS, Lot & Block Conditions:

- 20. Submit a full set of Street Lighting plans prepared per City Standards to daniel.silva1@dallas.gov. Street Lighting requirements are determined during the initial phase of review. Additional street lighting installations may be required to meet the photometric requirements of the 2019 Street Design Manual, Section 6. Photometric analysis will be required to support the submitted street lighting plan.
- 21. On the final plat, identify the property as Lot 1 in City Block A/7569.







