#### CITY PLAN COMMISSION

**THURSDAY, NOVEMBER 6, 2025** 

RECORD NO.: Plat-25-000088 SENIOR PLANNER: Sharmila Shrestha

**LOCATION:** Annarose Drive, west of Greenspan Avenue

**DATE FILED:** October 10, 2025 **ZONING:** R-7.5(A)

CITY COUNCIL DISTRICT: 3 SIZE OF REQUEST: 1.00-acre

**APPLICANT/OWNER:** Asuncion Lopez Zambrano

**REQUEST:** An application to create one 1.00-acre (43,561-square foot) lot from a tract of land in City Block 6909 on property located on Annarose Drive, west of Greenspan Avenue.

**SUBDIVISION HISTORY:** There has been no recent platting activity within close proximity to this request.

**STAFF RECOMMENDATION:** Section 51A-8.503 states that "lots must conform in width, depth, and area to the pattern already established in the adjacent areas, having due regard to the character of the area, its particular suitability for development, and taking into consideration the natural topography of the ground, drainage, wastewater facilities, and the proposed layout of the streets."

The lots are being created from a tract of land; therefore, it does not qualify for a residential replat and can be approved on the consent agenda.

- The properties to the north line of Annarose Drive have areas ranging in size from 16,075 square feet to 347,858 square feet and are zoned as R-7.5(A) Single Family District. (refer to the existing area analysis and aerial map)
- The properties to the south line of Annarose Drive have lot areas ranging in size from 16,083 square feet to 19,913 square feet and are zoned as R-7.5(A) Single Family District. (refer to the existing area analysis and aerial map)

The request lies in R-7.5(A) Single Family District which has a minimum lot area requirement of 7,500 square feet. The request is to create one 1.00-acre (43,561-square foot) lot.

The staff concludes that there is not an established lot pattern in the immediate area of the request, and the request complies with the requirements of Section 51A-8.503 and R-7.5(A) Single Family District; therefore, therefore, staff recommends approval of the request subject to compliance with the following conditions:

#### **General Conditions:**

1. The final plat must conform to all requirements of the Dallas Development Code, Texas Local Government Code, Texas Land Surveying Practices Act and the General Rules and Regulations of the Texas Board of Land Surveying.

- 2. Department of Development Services, Engineering Division must verify that the plat conforms with the water, wastewater, and easement requirements under the provisions of Chapter 49 of the Dallas City Code.
- 3. Compliance with all plans, contracts, ordinances, and requirements of the City of Dallas. Section 51A-8.102(a), (b), (c), and (d)
- 4. The number and location of fire hydrants must comply with the Dallas Fire Code.
- 5. Any new or existing structure may not extend across new property lines. Section 51A-8.503(e)
- 6. On the final plat, all easement abandonments, and ROW abandonments must be by separate instrument with the recording information shown on the face of the plat. A release from the Real Estate Division is required prior to the plat being submitted to the Chairman for signature.
- 7. On the final plat, include two boundary corners tagged with these coordinates: "Texas State Plane Coordinate System, North Central Zone, North American Datum of 1983 on Grid Coordinate values, No Scale and no Projection."
- 8. On the final plat, monument all set corners per the Monumentation Ordinance. Prior to submitting the final plat for the Chairman's signature. The monuments must be verified by the Chief City Surveyors Office in the Public Works Department. Section 51A-8.617
- 9. Provide ALL supporting documentation (i.e. deeds, plats, ordinances, easements...etc) with a completed Final Plat Checklist to the Survey Plat Review Group (**SPRG**) with the Final Plat Submittal <u>after</u> City Plan Commission Approval.
- 10. Prior to the final plat, submit a tree survey to the Arborist. A release from the arborist is required prior to an early release request or the recordation of the plat, whichever occurs first.
- 11. The number of lots permitted by this plat is one.

# Paving & Drainage Conditions:

- 12. Submit a full set of Civil Engineering Plans (drainage, paving, street signage/marking/lighting) prepared per City Standards by a licensed (TX) Professional Engineer to Engineering Division in Room 200, Oak Cliff Municipal Center (i.e. 311T/DP). Additions and alterations to the public infrastructure require approval and may require private development contracts with bonds.51A-8.102 (c); 8.601(b)(4),(5),(6),(7),(8),(9)
- 13. Detention may be required if the capacity of available outfall is not adequate to carry the developed runoff. Section 51A-8.611(c).
- 14. Place a note on the final plat stating "Lot-to-Lot drainage will not be allowed without proper City of Dallas Engineering Division approval" 51A 8.611(e)

### **Right-of way Requirements Conditions:**

15. On the final plat, dedicate 28 feet of right-of-way (via fee simple or street easement) from the established centerline of Annarose Drive. Section 51A 8.602(c); 51A 8.604(c).

### **Survey (SPRG) Conditions:**

- 16. Submit a completed Final Plat Checklist and All Supporting Documentation.
- 17. Show correct recording information for subject property.
- 18. Show all additions or tracts of land within 150' of property with recording information.

# **Dallas Water Utilities Conditions:**

- 19. Additional design information is required for assessment. Site plan must be submitted showing proposed development, building finished floor elevation, development, existing mains including downstream manhole, and proposed water and wastewater service locations. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.
- 20. Wastewater main improvements may be required by Private Development Contract. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.

# Street Light/ Real Estate/ Street Name Coordinator/ GIS, Lot & Block Conditions:

- 21. Additional design information needed to complete review. Provide a brief description of the proposed project and a copy of the site plan to <a href="mailto:daniel.silva@dallas.gov">daniel.silva@dallas.gov</a> to determine street lighting requirements.
- 22. Prior to the final plat submittal, contact Real Estate and identify the area on the lower right-hand side of the replat encroaching into Annarose Drive so it can be determined how to handle the encroachment.
- 23. On the final plat, change "Emberley Drive" to "Embrey Drive".
- 24. On the final plat, change "Annarose Drive" to "Annarose Drive (FKA Andrus Drive)".
- 25. On the final plat, identify the property as Lot 4 in City Block 15/6909.





