

REVIEW COMMENT SHEET
 BOARD OF ADJUSTMENT
 HEARING Tuesday, March 17, 2026 (A)

Has no objections

Has no objections if certain conditions are met
 (see comments below or attached)

Recommends denial
 (see comments below or attached)

No Comments

Pending

BDA245-044

BOA-25-00094

BOA-25-00096

BOA-25-000101

BOA-26-000004

BOA-25-000005

COMMENTS:

1) Recommends approval subject to compliance with site plan showing visibility triangle dimensions no less than 30' by 30' at corner of two public streets.

2) Has no objection to encroachment of visibility triangle at driveways, subject to site plan.

David Nevarez, P.E., PTOE, CFM, Engineering

Name/Title/Department

March 3, 2026

Date

Pease respond to each case and provide comments that justify or elaborate on your response. Dockets distributed to the Board will indicate those who have attended the review team meeting and who have responded in writing with comments.