

**CITY PLAN COMMISSION****THURSDAY, FEBRUARY 2, 2023****FILE NUMBER:** S223-061**SENIOR PLANNER:** Sharmila Shrestha**LOCATION:** North Central Expressway/ U.S Highway No. 75, south of Monticello Avenue**DATE FILED:** January 5, 2023**ZONING:** PD 193 (O-2)**PD LINK:** [https://dallascityhall.com/departments/city-attorney/Articles/PDF/Article\\_193.pdf](https://dallascityhall.com/departments/city-attorney/Articles/PDF/Article_193.pdf)**CITY COUNCIL DISTRICT:** 14    **SIZE OF REQUEST:** 1.5478-acres    **MAPSCO:** 35R**APPLICANT/OWNER:** Andrew Pollard

**REQUEST:** An application to create one 1.5478-acre lot from a tract of land in City Block E/1622 on property located on North Central Expressway/ U.S Highway No. 75, south of Monticello Avenue.

**SUBDIVISION HISTORY:**

1. S212-240 was a request north of the present request to replat a 0.9565-acre tract of land containing part of Lots 11 and 12, 14 through 16 and all of Lot 13 in City Block J/1623 to create one lot on property located on Monticello Avenue at McKinney Avenue, northeast corner. The request was approved on July 7, 2022 but has not been recorded.
2. S212-218 was a request northeast of the present request to replat a 1.085-acre tract of land containing all of Lots 1 through 4, part of Lots 19 through 24 in City Block 3/2016 to create one lot on property between McKinney Avenue and Central Expressway/ U.S. Highway No. 75 (FKA Keating Avenue), south of Webb Street. The request was approved on June 16, 2022 but has not been recorded.
3. S189-018 was a request southwest of the present request to replat a tract of land containing all of Lots 1 through 11 in City Block F/1623 to create one 1.839-acre lot on property located on McKinney Avenue between Monticello Avenue and Hester Avenue. The request was approved on November 15, 2018 and recorded on January 18, 2022.

**STAFF RECOMMENDATION:** The request complies with the requirements of PD 193 (O-2); therefore, staff recommends approval of the request subject to compliance with the following conditions:

**General Conditions:**

1. The final plat must conform to all requirements of the Dallas Development Code, Texas Local Government Code, Texas Land Surveying Practices Act and the General Rules and Regulations of the Texas Board of Land Surveying.
2. Department of Development Services, Engineering Division must verify that the plat conforms with the water, wastewater, and easement requirements under the provisions of Chapter 49 of the Dallas City Code.

3. Compliance with all plans, contracts, ordinances, and requirements of the City of Dallas. *Section 51A-8.102(a), (b), (c), and (d)*
4. The number and location of fire hydrants must comply with the Dallas Fire Code.
5. Any new or existing structure may not extend across new property lines. *Section 51A-8.503(e)*
6. On the final plat, all easement abandonments, and ROW abandonments must be by separate instrument with the recording information shown on the face of the plat. A release from the Real Estate Division is required prior to the plat being submitted to the Chairman for signature.
7. On the final plat, include two boundary corners tagged with these coordinates: "Texas State Plane Coordinate System, North Central Zone, North American Datum of 1983 on Grid Coordinate values, No Scale and no Projection."
8. On the final plat, monument all set corners per the Monumentation Ordinance. Prior to submittal of the final plat for the Chairman's signature. The monuments must be verified by the Chief City Surveyors Office in the Public Works Department. *Section 51A-8.617*
9. Provide ALL supporting documentation (i.e., deeds, plats, ordinances, easements...etc.) with a completed Final Plat Checklist to the Survey Plat Review Group (**SPRG**) with the Final Plat Submittal **after** City Plan Commission Approval.
10. Prior to the final plat, submit a tree survey to the Arborist. A release from the arborist is required prior to an early release request or the recordation of the plat, whichever occurs first.
11. The number of lots permitted by this plat is one.

**Paving & Drainage Conditions:**

12. Submit a full set of Civil Engineering Plans (drainage, paving, street signage/markings/lighting) prepared per City Standards by a licensed (TX) Professional Engineer to Engineering Division in Room 200, Oak Cliff Municipal Center (i.e., 311T/DP). Additions and alterations to the public infrastructure require approval and may require private development contracts with bonds. 51A-8.102 (c); 8.601(b)(4),(5),(6),(7),(8),(9)
13. Detention may be required if the capacity of available outfall is not adequate to carry the developed runoff. *Section 51A-8.611(c)*.
14. Place a note on the final plat stating "Lot-to-Lot drainage will not be allowed without proper City of Dallas Engineering Division approval" 51A 8.611(e)

**Right-of way Requirements Conditions:**

15. On the final plat, dedicate 7.5 feet of right-of-way (via fee simple) from the established center line of Alley. *Section 51A 8.602(c)*.
16. On the final plat, add the note: "TxDOT approval may be required for any driveway modification or new access point(s)." No citation.

17. Comply with PD 193 City Code- per PD

**Survey (SPRG) Conditions:**

18. Prior to final plat, submit a completed final plat checklist and all supporting documents.
19. On the final plat, show the correct recording information for the subject property. Platting Guidelines.
20. On the final plat, show how all adjoining right-of-way was created. Section 51A-8.403(a)(1)(A)(xxii).
21. On the final plat, show recording information on all existing easements within 150 feet of the property.
22. On the final plat, clarify if condominium regime is terminated.

**Dallas Water Utilities Conditions:**

23. Additional design information is required for assessment. Site plan must be submitted showing proposed development, building finished floor elevation, development, existing mains – including downstream manhole, and proposed water and wastewater service locations. Submit water/wastewater engineering plans to 320 E. Jefferson Blvd., Room 200, Attention: Water and Wastewater Engineering.

**Real Estate / Arborist / Street Name / GIS, Lot & Block Conditions:**

24. On the final plat, change “North Central Expressway (U.S. Highway No. 75)” to “Central Expressway / US Highway No. 75”. Section 51A-8.403(a)(1)(A)(xii)
25. On the final plat, identify the property as Lot 2 in City Block A/1622. Ordinance 1A, Page 131 pages 131-148, Section 2 (passed August 13, 1872).







