

Installation of Water and Wastewater Mains at (20) Locations

Contract No. (21-049/050)

Award Date (10/13/2021)

Location	Limits	Council District	Year Built Water	Year Built WW	Pipe Sizes & Type				Reason for Replacement	Potential Bond Project Conflicts	Street Condition
					Existing		Proposed				
					Water	WW	Water	WW			
Easement south of Jefferson Boulevard	from Coombs Creek Drive west	1	N/A	1932	N/A	6"-VCT & C.I.	N/A	10"-PVC	Wastewater Main in Poor Condition, No Water Main Replacement	None	N/A
Virginia Boulevard	from McLean Avenue east	1, City of Cockrell Hill	1942	1942	6"-E.C.I.	12"-VCT	6" & 8"-P.V.C.	12"-PVC	Water Quality, Wastewater Main in Poor Condition	None	D
Alley west of Midway Road	from Rosa Road to Wilada Drive	6	1950	1950	N/A	8"-VCT	8"-P.V.C.	8"-PVC	Water Main Fire Flow, water quality, Wastewater in Poor Condition	None	C, D
Morris Street	from Peoria Avenue east	6	N/A	1960	N/A	24"-VCT	N/A	27"-PVC	Wastewater Main in Poor Condition	None	Unknown
Peoria Avenue	from Singleton Boulevard north	6	1961	1961	6"-C.I.	15" & 18"-VCT	8"-PVC	16" & 30"-PVC	Water Main Capacity, Wastewater Main in Poor Condition	None	C
Jordan Valley Road	from Middlefield Road to east of Palomino Road	8	1987	1985	16"-PVC	15"-PVC	N/A	18" & 21"-PVC	Water Main in Good Condition, Wastewater Masterplan, Surcharge Reduction	None	E
Palomino Road	from Jordan Valley Road to Haymarket Road	8	1984	1986	12" & 16"-D.I.	10"-PVC	12" & 16" PVC	16"-PVC	Water Main Breaks, Wastewater Masterplan, Capacity, Surcharge Reduction	None	C
Alley between Lakeshore Drive and Lakewood Boulevard	from Pearson Drive to Copperfield Lane	9	1937	1937	4"-E.C.I.	6"-VCT	8"-P.V.C.	8"-PVC	Water Quality, Capacity, Wastewater in Poor Condition	None	C

Location	Limits	Council District	Year Built Water	Year Built WW	Pipe Sizes & Type				Reason for Replacement	Potential Bond Project Conflicts	Street Condition
					Existing		Proposed				
					Water	WW	Water	WW			
Alley between Lakeshore Drive and Velasco Avenue	Cambria Boulevard to Wendover Road	9	N/A	1937	N/A	6"-UNK	N/A	8"-PVC	Wastewater Main in Poor Condition, Capacity	None	N/A
Alleys/Easement between Avalon Avenue and north of Gaston Avenue	from Brendenwood Drive east	9	N/A	1936	N/A	6"-UNK	N/A	8"-PVC	Wastewater Main Breaks, Capacity, Re-route to ROW/Alley	None	N/A
Lorna Lane	from Brendenwood Drive to Pickens Street	9	1936	N/A	6"-E.C.I.	N/A	8"-P.V.C.	N/A	Water Quality, Capacity	None	E-Failed
Aberdeen Avenue	from Briar Meadow Drive to Airline Road	11	1965	N/A	6"-C.I.	N/A	8"-P.V.C.	N/A	Water Main Breaks, Capacity	None	C
Crest Meadow Drive	from Aberdeen Avenue to Briar Meadow Drive	11	1965	N/A	6"-C.I.	N/A	8"-P.V.C.	N/A	Water Main Breaks, Capacity	None	E
Easement north of Knoll Trail Drive	from Westgrove Drive east	11	1980	N/A	8"-D.I.	N/A	8"-P.V.C.	N/A	Water Main Breaks	None	Private Drive
Alley between Meadow Road and Waggoner Drive	from Preston Road to Tibbs Street	13	1959	N/A	4"-C.I.	N/A	8"-P.V.C.	N/A	Water Main Breaks, Capacity	None	E-Failed
Glendora Avenue	from Edgemere Road to Hillcrest Road	13	1949	N/A	8"-E.C.I.	N/A	8"-P.V.C.	N/A	Water Main Breaks	None	B

Location	Limits	Council District	Year Built Water	Year Built WW	Pipe Sizes & Type				Reason for Replacement	Potential Bond Project Conflicts	Street Condition
					Existing		Proposed				
					Water	WW	Water	WW			
Sexton Lane	from Midway Road to Merrell Road	13	1963	1960	6" & 8"-E.C.I.	6"-CONC	8"-P.V.C.	8"-PVC	Water Main Breaks, Wastewater Main in Poor Condition, Capacity	None	B
Webb Chapel Court	from Webb Chapel Road east	13	1961	1961	4"-C.I.	6"-VCT	8"-P.V.C.	8"-PVC	Water and Wastewater Mains in Poor Condition, Capacity	None	C
Beacon Street	from alley north of Junius Street to alley south of Worth Street	14	1938	1946	8"-C.I.	8"-CONC	8" & 10"-P.V.C.	8"-PVC	Water Main Breaks, Wastewater Main in Poor Condition	None	D
Saratoga Circle	from Woodcrest Lane to Woodcrest Lane	14	1956	1956	8"-C.I.	8"-CONC	8"-P.V.C.	8"-PVC	Water and Wastewater Mains in Poor Condition	None	C